



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

October 12, 2021

FOR: Attn: Jimmy Majewski
 Millenium Water
 647 Thompson Road
 P.O. Box 303
 Thompson, CT 06277

Sample Information

Matrix: DRINKING WATER
 Location Code: MILLENIU
 Rush Request: 72 Hour
 P.O.#: 90153

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date Time
 10/06/21 20:00
 10/08/21 13:15

Laboratory Data

SDG ID: GCJ52377
 Phoenix ID: CJ52377

Project ID: DR HELEN BALDWIN SCH
 Client ID: TEACHERS LOUNGE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	0.033	0.002	1	mg/L	1.3			10/12/21	EK	E200.7
Lead	0.0071	0.0010	1	mg/L	0.015			10/12/21	EK	E200.5
Total Metal Digestion	Completed							10/11/21	TH/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 143 Secondary Goals; CT Public Health Code 19-13-B102. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

October 12, 2021

Official Report Release To Follow



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

October 12, 2021

FOR: Attn: Jimmy Majewski
 Millenium Water
 647 Thompson Road
 P.O. Box 303
 Thompson, CT 06277

Sample Information

Matrix: DRINKING WATER
 Location Code: MILLENIU
 Rush Request: 72 Hour
 P.O.#: 90153

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

10/06/21
 10/08/21

Time

20:01
 13:15

Laboratory Data

SDG ID: GCJ52377
 Phoenix ID: CJ52378

Project ID: DR HELEN BALDWIN SCH
 Client ID: ALL GENDERS BATHROOM NEAR SCIENCE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	0.055	0.002	1	mg/L	1.3			10/12/21	EK	E200.7
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/12/21	EK	E200.5
Total Metal Digestion	Completed							10/11/21	TH/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 143 Secondary Goals; CT Public Health Code 19-13-B102. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

October 12, 2021

Official Report Release To Follow



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

October 12, 2021

FOR: Attn: Jimmy Majewski
 Millenium Water
 647 Thompson Road
 P.O. Box 303
 Thompson, CT 06277

Sample Information

Matrix: DRINKING WATER
 Location Code: MILLENIU
 Rush Request: 72 Hour
 P.O.#: 90153

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

10/06/21
 10/08/21

Time

20:02
 13:15

Laboratory Data

SDG ID: GCJ52377
 Phoenix ID: CJ52379

Project ID: DR HELEN BALDWIN SCH
 Client ID: ROOM 106

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	0.123	0.002	1	mg/L	1.3			10/12/21	EK	E200.7
Lead	0.0019	0.0010	1	mg/L	0.015			10/12/21	EK	E200.5
Total Metal Digestion	Completed							10/11/21	TH/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 143 Secondary Goals; CT Public Health Code 19-13-B102. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

October 12, 2021

Official Report Release To Follow



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

October 12, 2021

FOR: Attn: Jimmy Majewski
 Millenium Water
 647 Thompson Road
 P.O. Box 303
 Thompson, CT 06277

Sample Information

Matrix: DRINKING WATER
 Location Code: MILLENIU
 Rush Request: 72 Hour
 P.O.#: 90153

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

10/06/21
 10/08/21

Time

20:03
 13:15

Laboratory Data

SDG ID: GCJ52377
 Phoenix ID: CJ52380

Project ID: DR HELEN BALDWIN SCH
 Client ID: ROOM 230 WINDOW SINK

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	0.099	0.002	1	mg/L	1.3			10/12/21	EK	E200.7
Lead	0.0022	0.0010	1	mg/L	0.015			10/12/21	EK	E200.5
Total Metal Digestion	Completed							10/11/21	TH/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 143 Secondary Goals; CT Public Health Code 19-13-B102. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

October 12, 2021

Official Report Release To Follow



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

October 12, 2021

FOR: Attn: Jimmy Majewski
 Millenium Water
 647 Thompson Road
 P.O. Box 303
 Thompson, CT 06277

Sample Information

Matrix: DRINKING WATER
 Location Code: MILLENIU
 Rush Request: 72 Hour
 P.O.#: 90153

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

Time

10/06/21 20:04
 10/08/21 13:15

Laboratory Data

SDG ID: GCJ52377
 Phoenix ID: CJ52381

Project ID: DR HELEN BALDWIN SCH
 Client ID: NURSES OFFICE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	0.068	0.002	1	mg/L	1.3			10/12/21	EK	E200.7
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/12/21	EK	E200.5
Total Metal Digestion	Completed							10/11/21	TH/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 143 Secondary Goals; CT Public Health Code 19-13-B102. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

October 12, 2021

Official Report Release To Follow



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

October 12, 2021

FOR: Attn: Jimmy Majewski
 Millenium Water
 647 Thompson Road
 P.O. Box 303
 Thompson, CT 06277

Sample Information

Matrix: DRINKING WATER
 Location Code: MILLENIU
 Rush Request: 72 Hour
 P.O.#: 90153

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date Time
 10/06/21 20:05
 10/08/21 13:15

Laboratory Data

SDG ID: GCJ52377
 Phoenix ID: CJ52382

Project ID: DR HELEN BALDWIN SCH
 Client ID: BUBBLER 1 NEAR SUPERINTENDENT'S OFFICE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	0.094	0.002	1	mg/L	1.3			10/12/21	EK	E200.7
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/12/21	EK	E200.5
Total Metal Digestion	Completed							10/11/21	TH/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 143 Secondary Goals; CT Public Health Code 19-13-B102. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

October 12, 2021

Official Report Release To Follow



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

October 12, 2021

FOR: Attn: Jimmy Majewski
 Millenium Water
 647 Thompson Road
 P.O. Box 303
 Thompson, CT 06277

Sample Information

Matrix: DRINKING WATER
 Location Code: MILLENIU
 Rush Request: 72 Hour
 P.O.#: 90153

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date Time

10/06/21 20:06
 10/08/21 13:15

Laboratory Data

SDG ID: GCJ52377
 Phoenix ID: CJ52383

Project ID: DR HELEN BALDWIN SCH
 Client ID: BUBBLER 2 NEAR CAFE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	0.085	0.002	1	mg/L	1.3			10/12/21	EK	E200.7
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/12/21	EK	E200.5
Total Metal Digestion	Completed							10/11/21	TH/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 143 Secondary Goals; CT Public Health Code 19-13-B102. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

October 12, 2021

Official Report Release To Follow



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

October 12, 2021

FOR: Attn: Jimmy Majewski
 Millenium Water
 647 Thompson Road
 P.O. Box 303
 Thompson, CT 06277

Sample Information

Matrix: DRINKING WATER
 Location Code: MILLENIU
 Rush Request: 72 Hour
 P.O.#: 90153

Custody Information

Collected by:
 Received by: CP
 Analyzed by: see "By" below

Date

Time

10/06/21 20:07
 10/08/21 13:15

Laboratory Data

SDG ID: GCJ52377
 Phoenix ID: CJ52384

Project ID: DR HELEN BALDWIN SCH
 Client ID: BUBBLER 3 NEAR TEACHERS LOUNGE

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	0.137	0.002	1	mg/L	1.3			10/12/21	EK	E200.7
Lead	< 0.0010	0.0010	1	mg/L	0.015			10/12/21	EK	E200.5
Total Metal Digestion	Completed							10/11/21	TH/BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 143 Secondary Goals; CT Public Health Code 19-13-B102. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

October 12, 2021

Official Report Release To Follow

Sample Criteria Exceedances Report

GCJ52377 - MILLENIU

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

*** No Data to Display ***

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.

Millenium Water LLC

A Division of LaFramboise Water Service, Inc.
 647 Thompson Road, PO Box 303
 Thompson, CT 06277
 Phone: 1-800-624-2327
 Fax: 860-923-9971

Connecticut Division

Contract Operations
 Certified Operators
 Monitoring/Reporting
 Treatment Systems

FOR LAB USE ONLY

Lab WO #

Project Manager

Date Collected: 10/6/2021

PWS Class NTNC

Routine YES

Is Source Treated? NO

PWS ID # CT 0221122

PWS Name: Dr. Helen Baldwin Sch

Town: Canterbury

Job # 90153

WSF ID:	ID	Sampling Point Description	Duration	Sample Matrix	Date Collected	Time Collected	Sample Type	# of Bottles	Analysis Requested	
									Lead &	Copper
52377		Teachers Lounge	A	DS	10/6/2021	10:00 PM	G	1	X	
52378		All Genders bathroom near science	A	DS	10/6/2021	10:01 PM	G	1	X	
52379		Room 106	A	DS	10/6/2021	10:02 PM	G	1	X	
52380		Room 230 Window Sink	A	DS	10/6/2021	10:03 PM	G	1	X	
52381		Nurses Office	A	DS	10/6/2021	10:04 PM	G	1	X	
52382		Bubbler 1 Near Superintendent's office	A	DS	10/6/2021	10:05 PM	G	1	X	
52383		Bubbler 2 Near Café	A	DS	10/6/2021	10:06 PM	G	1	X	
52384		Bubbler 3 Near Teacher's Lounge	A	DS	10/6/2021	10:07 PM	G	1	X	

CUSTODY TRANSFER		DATE	TIME	COMMENTS
Sampler:	Client	10/6/2021		
Relinquished By:	KB	10/7/2021	1:15 PM	3 DAY
Received By:		10/8/21	0912	Rush
Relinquished By:				
Received By:	Ganna John	10/8/21	1315	

WCIP

Conditions Upon Receipt: Cooled Ambient 2.5 C Upon receipt at Lab. 10/7/2021